

# ONDA<sup>®</sup>

## VALVE & WATER METER

Pembelian hubungi:

**PureWaterCare**

**Water Treatment Management**

Office : Apartemen Sentra Timur Residence Tower Hijau Retail H08 EB Pulo Gebang Jakarta Timur

Workshop : Jl. Nusa Indah Raya Blok 37 No 10 Perumnas Klender Jakarta Timur

Telp: 021-7053-8248 , Fax : 021-862-2375, Fax: 021-4870-3967 , Hp : 0852-1830-0576

Website: [www.purewatercare.com](http://www.purewatercare.com) | Email : [purewatercare@gmail.com](mailto:purewatercare@gmail.com)

### ROTARY-VANE DRY-DIAL MAGNET-DRIVE WATER METER NANO

#### FEATURE :





- \* DRY - DIAL
- \* MULTI - JET
- \* MAGNETIC DRIVE
- \* ANTIMAGNETIC CONSTRUCTION
- \* MEASURING ACCURACY CONFORM TO ISO 4064 CLASS B STANDARD



# ONDA<sup>®</sup>

## VALVE & WATER METER

### TECHNICAL DATA

|   |                      |                   |  |  |  |
|---|----------------------|-------------------|--|--|--|
| Nominal Diameter  | DN                   | mm                | 15   | 20   | 25   |
| Nominal Pressure  | PN                   | Bar               | 10   | 10   | 10   |
| Smallest Readable   | Vol.                 | 1                 | 0.1  | 0.1  | 0.1  |
| Registration Capacity   |                      | m <sup>3</sup>    | 99999  | 99999  | 99999  |
| Operating Temperature   | Max                  | °C                | 50   | 50   | 50   |
| Installation Position   |                      | Pipe Meter Head   |  |  |  |
| Maximal Flow Rate   | Q <sub>max</sub>     | m <sup>3</sup> /h | 3  | 5  | 7  |
| Nominal Flow Rate   | Q <sub>n</sub>       |                   | 1.5  | 2.5  | 3.5  |
| Transitional Flow Rate  | Q <sub>t</sub>       |                   | 0.12   | 0.20   | 0.28   |
| Minimum Flow Rate   | Q <sub>min</sub>     |                   | 0.03   | 0.05   | 0.07   |
| Error Limits  | Q <sub>max..Qt</sub> | %                 | < + 2  | < + 2  | < + 2  |
|   | Q <sub>min</sub>     |                   | < + 5  | < + 5  | < + 5  |
| Dimensions in mm :  |                      | L :               | 165  | 190  | 260  |
|  |                      | B :               | 99   | 99   | 104  |
|   |                      | H :               | 104  | 106  | 120  |

\* Subject to modification without notice

Pembelian hubungi:

**PureWaterCare**

**Water Treatment Management**

Office : Apartemen Sentra Timur Residence Tower Hijau Retail H08 EB Pulo Gebang Jakarta Timur

Workshop : Jl. Nusa Indah Raya Blok 37 No 10 Perumnas Klender Jakarta Timur

Telp: 021-7053-8248 , Fax : 021-862-2375, Fax: 021-4870-3967 , Hp : 0852-1830-0576

Website: [www.purewatercare.com](http://www.purewatercare.com) | Email : [purewatercare@gmail.com](mailto:purewatercare@gmail.com)